



progetti

Renewable energy application in o&g fields

Fuel gas substitution in production site

San Donato Milanese, 18.10.2017



The Basis

Project framework

- *Oil & Gas production site (North Africa)*
- *53 GWh: yearly power consumption of site*
- *Self-standing site:*
 - *2 x 100% genset*
 - *Feed with plant produced gas*
 - *Required availability for power generation: 98%*
- *Oil&Gas production ruled by PSA (cost recovery mechanism)*
- *Profitable sale gas tariff*


Renewable Source Selection

- *Availability of land area for PV field installation*
- *Good productivity for PV technology*

- *Performance*
 - *eHR: 13,274 kJ/kWh_e*
 - *FG consumption: 0,352 Sm³/kWh_e
(18,7 MMSCM/year)*
 - *CO₂ production: 0,749 kg/kWh_e
(39,7 ktonn/year)*

- *Good fit with power requirement*

PV Application: the Challenge



- *Sudden variation of solar source could generate unpredictable loss of power leading to plant shutdown and associated loss of production*
- *New generation concept is to be capable to manage the unpredictability of renewable source and ensure the availability requirement to support site production*

Screened Scenarios



100%

Power requirement fully generated by PV plant, conventional generation totally removed

- *System composed by PV plant and storage*
- *Storage system sized to cover sudden variation and long-term solar source unavailability (“no-sun” day, night shift, etc.)*
- *PV plant sized to provide power to users and to ensure refill of storage system*

Minimal

Power mainly by conventional source, renewable limited by flexibility requirement

- *Conventional generation run in parallel with PV*
- *PV sized in order to not overcome conventional generation capability to handle sudden variation (typically, 5÷15% of total load)*
- *No storage required*



Hybrid

Conventional generation run at minimum, storage to cover sudden variation

- *Conventional generation run in parallel with PV*
- *Conventional generation run at minimum turndown to be ready for night shift and to cover daily sudden solar source unavailability*
- *PV sized to fill the gap with total load requirement*
- *Optimized storage provided to handle transient when renewable run off and conventional generation ramp up to cover full load demand*

eniprogetti

The Solution



- *Network stability analysis determine the optimized storage sizing according with considered power system specific dynamic behavior*
- *Availability of hybrid generation system relies on EMS (Electrical Management System) to be designed in order to withstand the transient scenarios and manage the three power sources (conventional, PV, storage)*


Case Study Findings




<i>DATA</i>	<ul style="list-style-type: none"> • 53 GWh/year • 98% availability 	
	<i>EXISTING plant</i>	<i>HYBRID Solution</i>
<i>FACILITIES</i> <small>(additional for Hybrid)</small>	<ul style="list-style-type: none"> • 2x100% x 8,0 MW GenSet 	<ul style="list-style-type: none"> • 5,0 MW_p PV Plant • 0,5 MWh Storage • Enhanced EMS
PERFORMANCE	<ul style="list-style-type: none"> • eHR: 13 274 kJ/kWh_e • FG consumption: 0,352 Sm³/kWh_e (18,7 MMSCM/y) • CO₂ Production: 0,749 kg/kWh_e (39,7 ktonn/year) 	<ul style="list-style-type: none"> • eHR: 11 119 kJ/kWh_e • FG consumption: 0,295 Sm³/kWh_e (Δ=16,2%) (15,6 MMSCM/y) • CO₂ Production: 0,627 kg/kWh_e (33,3 ktonn/year)
COST	-	8÷10 M€



Overview on other scenarios



Δ%HR	Minimal	Hybrid	100 %
Range	1,1÷5,4%	4,4÷17,9%	70÷90%
Study	3,5%	16,2%	80%



k€/Δ%HR MW	Minimal	Hybrid	100 %
Range	72÷148	21÷127	314÷1006
Study	77	82	379